

Right-of-Way Specifications

Rural Utility Service R 1-40

- 1.) Right-of-Way (ROW) work will be the responsibility of the member, at their expense, to be cleared to the satisfaction of the Cooperative.
- 2.) For new power line construction, ROW is to be cut to R 1-40 specifications which require a 40 foot (minimum) width ROW at the ground, and vertically to the tree tops.
- 3.) Trees that require removal are to be cut as low as applicable, generally less than 3 inches.
- 4.) Underbrush and tree tops are to be *felled or stacked* to either side of the 40 foot ROW corridor.
- 5.) Logs are to be moved to either side of the ROW, allowing access for power line construction crews.

