

Right-of-Way Specifications

Rural Utility Service R 1-40

- 1.) Right-of-Way (ROW) work will be performed by Cooperative crews, or contractors hired by the Cooperative.
- 2.) For new power line construction, ROW will be cut to R 1-40 specifications which require a 40 foot (minimum) width ROW at the ground, and vertically to the tree tops.
- 3.) Trees that require removal will be cut as low as applicable, generally less than 3 inches.
- 4.) Underbrush and tree tops will be *felled or stacked* to either side of the 40 foot ROW corridor.
- 5.) Logs will be moved to either side of the ROW, allowing access for power line construction crews. Logs may be cut to mill lengths of 8'-6", 10'-6", ect.
- 6.) Trees on the outside edges of the 40 foot ROW corridor will be removed if side-trimming the tree could cause the tree to decay.



Black River Electric Cooperative

Your Touchstone Energy® Partner

